

ADDENDA NO. 1 (Group-I)

Pursuant to the pre-bid conference held on 28.07.2023 at Patna, following Amendments is issued in the terms and conditions of the contract document (Vol-I) in respect of the tender for “Restoration and O&M” works of Group-I.

1. Normative energy for Dehri-On-Sone Project

- (i) Normative energy for this project is 18.54 + approximately 33 % increase due to operation of escape arrangement (Total 24.60 MU).
- (ii) The increase in energy generation due to escape arrangement shall be more than 33% but to take care of the variation in the discharge in canal during closer period of 4 months, the increase in generation has been kept as 33%
- (iii) Further, for calculation of penalty, now the normative energy will be considered as 23.175 MU (only 25 % increase due to operation of escape arrangement) to take care of further exigencies. It is therefore table of clause no 4.1 of tender document may be amended as follows:

Sl. No.	Name of Project	Installed Capacity (MW)	Normative Energy (Annual) in MUs
1	Dehri-on-Sone SHP	6.6	i. 18.54 (before operation of escape regulator) ii. 24.60* (after operation of escape arrangement)

- * For calculation of penalty, the normative energy shall be considered as 23.175 MU